

11400 Robinwood Drive · Hagerstown, MD 21742-6514

## RFB HCC25-002 Parking Lot and Road Repair Services

**Addendum 1**, posted on August 12, 2024, consists of questions received prior to the question deadline.

## **Questions & Answers:**

- Q1: Please see attachment (Campus Map a.) for your reference. We have highlighted the areas in yellow where we believe the roadways Scholar Dr. and Shea Dr. are to be crack filled and line striped. The areas highlighted in pink are the parking lots stated in the Bid documents to be crack filled, seal coated, and line striped. Please confirm these are the areas and general details to be performed.
- A1: Correct, the pink highlighted areas are the parking lots and the yellow is the roadways requested.
- Q2: Crosswalks-Some are painted differently than others. Would you like to have all of them repainted in the same uniform style or just to repaint as is? Please see attachment (Crosswalks a. & Crosswalks b.) for your reference.
- A2: We would like to have all Crosswalks uniform, using the wide stripes as in "crosswalks b.pdf".
- Q3: Crab Grass-There are a number of areas where the crab grass has grown thru the pavement, please clarify scope of work for this. Please see attachment (Crab Grass a. & Crab Grass b.) for your reference.
- A3: In the area in the attachment, we are looking to have the grass removed (our grounds crew will likely have this done) and fill the cracks as they are unless in the professional opinion it would need to be cut out and patched which we would want to have a separate quote for any major repairs of this nature.

- Q4: In reference to the Bid Documents page 15 2.6 a. Please clarify the statement, "The contractor shall install a single coat grade CRS-2 in conformance with the MDOT-SHA Standard Specifications for Construction and Materials per Section 503 and 904.03."This spec is typically referenced in Chip Seal or Micro Paving <u>not</u> for Seal Coating.
- A4: Please disregard 2.6a and use the information in 2.6b and 2.6c in reference to seal coating requirements.

## **Upcoming Deadlines:**

The proposal closing is **August 20, 2024 at 10:00 AM**. Reference the RFB for submission details. Please pay careful attention to the requirement to be registered on Bid Locker in order to submit a proposal for this project.

Respectfully submitted,

aliciaCullop

Alicia Cullop

**Director of Procurement Services** 

## CAMPUS MAP







